



May 20, 1992

New York City  
Department of  
Environmental  
Protection

Mr. John Karell, Jr., P.E.  
Public Health Director  
Division of Environmental Health Services  
Putnam County Department of Health  
110 Old Route Six Center  
Carmel, New York 10512

Bureau of Water  
Supply & Wastewater  
Collection

RE: Sanitary Sewers  
Lake Mahopac Area - Route 6N  
(T) Carmel

Sources Division  
(914) 742-2012/3

Dear Mr. Karell:

Division of Drinking  
Water Quality Control  
(914) 742-2080

I have received a copy of your letter of April 15th to John and Susan Hoy Crawford regarding the installation of a sewer line in the Route 6N, Lake Mahopac Area (see attached).

P.O. Box 66  
Valhalla, New York 10595-  
1336

Sewer service in this area would require an expansion of the sewer district. Such plans are not part of the facility plan for the new Mahopac Wastewater Treatment Plant being designed under the Order on Consent.

ALBERT F. APPLETON  
Commissioner

The proposed new facility has been sized to treat existing sewer district flow. The design flow includes a significant contribution from the presently excessive inflow and infiltration (I/I). This condition must be corrected before the City could entertain an expansion of the sewer district. In addition, a proposal for an expansion of the sewer district would require a study by the Town of Carmel to determine the adequacy of existing treatment and the specific areas to be served by the sewer district.

JOSEPH P. CONWAY, P.E.  
Deputy Commissioner

If you have any questions, please contact Joseph Landau at 742-2051.

Very truly yours,

George Mekenian, P.E.  
Chief, Sources Division

attachment

cc: Senator Mary Goodhue, New York State  
Richard Othmer, Supervisor, Town of Carmel  
Vincent Soukup, P.E., Town of Carmel  
Joseph Landau, New York City